


# User manual ALFA(NET) 51

## Rail-Thermostat.



VDH doc. 032797

Version: v1.2

Date: 20-02-2007

Software: ALFANET51

File: Do032797.WP8

Range: -50/+50,0°C

### \* Installation.

On the connection diagram of the **ALFA(NET) 51** is shown how the sensors, power supply and relays are to be connected. After connecting the **ALFA(NET) 51** to the power supply, a self test function is started. As this test is finished, the measured temperature appears in the display. Normally this is the temperature of sensor-1, unless sensor-2 is active as control sensor (P05=1) in that case the average temperature of both sensors is displayed and used for control. The **ALFANET 51** is by use of the **ALFANET PC-INTERFACE** controllable on the PC.

### \* Control.

The **ALFA(NET) 51** thermostat can be controlled by four pushbuttons on the front. These keys are:

- SET** - view / change the setpoint.
- UP** - increase the setpoint.
- DOWN** - decrease the setpoint.
- MODE** - relay status key.

### \* Viewing setpoint.

By pushing the **SET** key the setpoint appears in the display. The decimal point of the last display starts blinking. A few seconds after releasing the **SET** key the setpoint disappears and the measured temperature is shown again in the display.

### \* Changing setpoint.

Push the **SET** key and the setpoint appears in the display. Release the **SET** key. Now push the **SET** key again together with the **UP** or **DOWN** keys to change the setpoint. A few seconds after releasing the keys the measured temperature shows again in the display.

### \* Viewing the individual sensors.

By pressing the **UP** and **DOWN** key together, the individual sensors can be shown in the display. After releasing the keys, the measured temperature of sensor-1 can be shown by pushing the **UP** key or the measured temperature of sensor-2 can be shown by pushing the **DOWN** key. A few seconds after releasing the keys the (average) temperature shows again in the display.

### \* Status of the Relays.

By pushing the **MODE** key the display shows the status of the relays. Each display segment shows the status of the relay output, showing 0=off and 1=on. The code 110 means relay 1 and 2 are on and relay 3 is off.



\* **Setting internal parameters.**

Next to the adjustment of the setpoint, internal settings can be made like differential, sensor offset, setpoint range and the functions of the thermostat.

Push the **DOWN** key for more than 10 seconds, to enter the 'Internal Programming Menu'. In the left display the upper- and lower-segment are blinking. With the **UP** and **DOWN** keys the required parameter can be selected (see the parameter table).

If the required parameter is selected, the value can be read-out by pushing the **SET** key. Pushing the **UP** or **DOWN** key to change the value of this parameter.

If after 20 seconds no key is pushed, the **ALFA(NET) 51** changes to the normal operation mode.

\* **Adjustment sensors.**

Sensor-1 can be adjusted by using the Sensor Offset parameter 06 and Sensor-2 can be adjusted by using the Sensor Offset parameter 07. Indicates a Sensor e.g. 2°C too much, the according Sensor Offset has to be decreased by 2°C.

\* **Error messages.**

In the display of the **ALFA(NET) 51** the following error messages can appear:

<b>LO</b>	- Minimum alarm.	<u>Solution E1,E2:</u>
<b>HI</b>	- Maximum alarm.	- Check if the sensor is connected correctly.
<b>E1</b>	- Sensor-1 failure.	- Check sensor (1000Ω at 25°C).
<b>E2</b>	- Sensor-2 failure.	- Replace sensor.
<b>EEE</b>	- Settings are lost.	<u>Solution EEE:</u>
		- Reprogram the settings.

**-L-** - In case of sensor short-circuit the display alternates between error-code **E..** and **-L-**, as indication for a short-circuit sensor.

**-H-** - In case of open-circuit sensor the display alternates between error-code **E..** and **-H-**, as indication for an open circuit sensor.

**Reset Alarm.** When an error-message appears it can be reset by pushing the **SET** key. The function of this key depends on parameter P37.

\* **Technical data.**

Type	: ALFA(NET) 51 rail thermostat
Range	: -50/+50,0°C, above -10°C display per 0,1°C
Supply	: 12Vac 50/60Hz (-5/+10%)
Display	: 3-digit 7-segment display
Relays	: Ry1= SPST(NO)250V/8A (cos φ=1) of 250V/5A (cos φ=0.4) Ry2= SPST(NO)250V/8A (cos φ=1) of 250V/5A (cos φ=0.4) Ry3= SPDT(NO/NC)250V/8A (cos φ=1) of 250V/5A (cos φ=0.4) Relays have one common (C).
Control	: By push buttons on front.
Front	: Polycarbonate IP65
Sensors	: 2x SM 811/2m (PTC 1000Ω/25°C).
Communication	: RS485-Network (2x twisted pair shielded cable min. 0,75mm <sup>2</sup> )
Dimensions	: 90 x 71 x 58mm (HWD)
Panel cut out	: 46 x 71mm (HW) for front mounting
Accuracy	: ± 0,5% of the range.

- Provided with memory protection during power failure.
- Connections with screw terminals on the back side.
- Equipped with sensor failure detection.
- Special versions are on request available.




\* **Parameters ALFA(NET) 51**


Para-Meter	Description Parameter	Range	Standard value
01	Function Relay 1	1 = Cool 2 = Heat	1
02	Function Relay 2	3 = Alarm 1 = Cool 2 = Heat	2
03	Function Relay 3	3 = Alarm 1 = Cool 2 = Heat 3 = Alarm	3
05	Function sensor-2	0 = Not 1 = Control 2 = Alarm	0
06	Offset temperature sensor-1	-15.0..+15.0 °C	0.0
07	Offset temperature sensor-2	-15.0..+15.0 °C	0.0
10	Switch on relay 2 by	0 = Temperature 1 = Time	0
11	Switch on relay 3 by	0 = Temperature 1 = Time	0
12	Switch on delay relay 2	0.. 99 Minutes	15
13	Switch on delay relay 3	0..99 Minutes	15
14	Switching differential relay 1	0.1..15.0 °C	0.5
15	Setpoint offset relay 1	-15..+15 °C	0.0
16	Switching differential relay 2	0.1..15.0 °C	0.5
17	Setpoint offset relay 2	-15..+15 °C	0.0
18	Switching differential relay 3	0.1..15.0 °C	0.5
19	Setpoint offset relay 3	-15..+15 °C	0.0
20	Switch on delay cooling	0..99	0
21	Switch off delay cooling	0..99	0
22	Parameter 20/21 in Sec. or Min.	0 = Seconds 1 = Minutes	0
23	Minimum on-time cooling	0..99 Minutes	0
24	Minimum off-time cooling	0..99 Minutes	0
25	Minimum setpoint	-50.0..+50.0 °C	-50
26	Maximum setpoint	-50.0..+50.0 °C	+50
27	Read-out above -10 °C per 1 °C	0 = No 1 = Yes	0
30	Alarm type (to setpoint)	0 = None 1 = Absolute 2 = Relative	1
31	Minimum alarm setpoint	-50.0..+50.0 °C	-50
32	Maximum alarm setpoint	-50.0..+50.0 °C	+50
33	Time delay minimum alarm	0..99 Minutes	0
34	Time delay maximum alarm	0..99 Minutes	0
35	Relay function alarm relay	0 = Watch 1 = Control	0
36	Reset alarm relay after recovering alarm	0 = No 1 = Yes	0
37	Reset alarm relay after manual reset	0 = No 1 = Yes	0
40	Start up delay after power failure	0..99 Minutes	0
41	Forced relay function at sensor failure	0 = None 1 = Cool 2 = Heat	0
90	Network number	1..250	1
95	Software version	0..255	0
96	Production year	00..99	0
97	Production week	1..52	1
98	Serial number (x1000)	0..255	0
99	Serial number (units)	0..999	0



\* **Dimensions.**



\* **Connections.**



\* **Address.**

VDH Products BV  
 Produktieweg 1  
 9301 ZS Roden  
 The Netherlands

Tel: +31 (0)50 30 28 900  
 Fax: +31 (0)50 30 28 980  
 Email: info@vdhproducts.nl  
 Internet: www.vdhproducts.nl

